



CITY OF CIBOLO, TEXAS  
CAPITAL IMPROVEMENT PROJECT  
TOWN CREEK DRAINAGE PROJECT PHASE I

**ADDENDUM NO. 2**

**FEBRUARY 9, 2021**

PROJECT NAME: Town Creek Drainage Project Phase I  
BID DATE: Tuesday, February 16, 2021  
PLACE: Office of the City Clerk, 200 S. Main Street, Cibolo, Texas 78108

This addendum should be included in and be considered part of the plans and specifications for the above named project. The contractor shall be required to sign an acknowledgement of the receipt of this addendum and submit with their bid.

---

**BID OPENING SCHEDULED FOR TUESDAY, FEBRUARY 16, 2021 AT 2:00 PM CENTRAL TIME.**

Use the following link to log into the Zoom meeting:

Join Zoom Meeting

<https://us02web.zoom.us/j/81521036780?pwd=ckNMSjVjMjVQSDlyNTI3NEdmRDdUdz09>

Meeting ID: 815 2103 6780

Passcode: 654812

One tap mobile

+13462487799,,81521036780#,,,,\*654812# US (Houston)

+12532158782,,81521036780#,,,,\*654812# US (Tacoma)

Dial by your location

+1 346 248 7799 US (Houston)

+1 253 215 8782 US (Tacoma)

+1 669 900 6833 US (San Jose)

+1 312 626 6799 US (Chicago)

+1 929 205 6099 US (New York)

+1 301 715 8592 US (Washington DC)

Meeting ID: 815 2103 6780

Passcode: 654812

Find your local number: <https://us02web.zoom.us/j/81521036780>



CITY OF CIBOLO, TEXAS  
CAPITAL IMPROVEMENT PROJECT  
TOWN CREEK DRAINAGE PROJECT PHASE I

### CONTRACTOR QUESTIONS

1. On Sheet 3 there are two stockpile areas.

It is intended that excavated material be moved by the most cost effective means. Off-road equipment is allowable. Schaeffer Road can be closed between Haeckerville and Main Street to accommodate off-road vehicles. It is noted that there are water transfer mains crossing Schaeffer Road, including a 30" main that is required to be protected.

2. Is there a water source available to revegetate the area?

Yes, the City will provide a "hydrant meter" within a half-mile (1/2) of the project site for revegetation use.

3. Who is responsible for the water main?

It is the responsibility of the contractor to preserve the integrity of all utilities in or near the project site from damage that may result from project activities.

4. What is the completion schedule?

90 days for substantial completion

120 days for final completion

5. Is there a Storm Water Pollution Prevention Plan (SWPPP) booklet?

A SWPPP booklet is included with this Addendum

### PROJECT MANUAL

6. Remove "003 Bid Form (C-410)" in its entirety and replace with "003 Bid Form (C-410)" which is included with this addendum. The following revisions were made:

- a. Article 6-Time of Completion. "The work will be substantially complete within 90 calendar days . . . , and will be completed and ready for final payment in accordance with Paragraph 15.06 of the General Conditions within 120 calendar days after the date when the Contract Times commence to run."



CITY OF CIBOLO, TEXAS  
CAPITAL IMPROVEMENT PROJECT  
TOWN CREEK DRAINAGE PROJECT PHASE I

RECEIPT OF ADDENDUM NUMBER TWO (2) IS HEREBY ACKNOWLEDGED FOR PLANS AND SPECIFICATIONS FOR CONSTRUCTION OF **TOWN CREEK DRAINAGE PROJECT PHASE I.**

FOR WHICH BIDS WILL BE OPENED ON **TUESDAY, FEBRUARY 16, 2021 AT 2:00 P.M. LOCAL TIME**

THIS ACKNOWLEDGEMENT MUST BE SIGNED AND RETURNED WITH THE BID PACKAGE.

Company Name: \_\_\_\_\_

Address: \_\_\_\_\_

City/State/Zip Code: \_\_\_\_\_

Date: \_\_\_\_\_

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Print Name/Title

**END OF ADDENDUM 2**